



OFFICE OF ADMINISTRATIVE TRIALS AND HEARINGS
Hearings Division

DECISION

Caroline Kane, Esq. - Nacmias Law Firm, PLLC 592 Pacific Street, 1st Floor Brooklyn, NY 11217	Summons No: 039123787X et al. (1 Summons) DEPT OF BUILDINGS, -against- SHRI SIDHDHY VANAYAK, INC Hearing Date: 06/30/2025 Hearing Location: Remote Type of Hearing: By Telephone
--	---

Total Penalty Amount: \$1,250.00
Community Service(Hr): Not Applicable

SUMMONS #	SUMMARY DISPOSITION	DATE OF OCCURRENCE	PLACE OF OCCURRENCE
039123787X	Sustained	09/03/2024	1119 EAST GUNHILL ROAD Bronx

LINE ITEM	OATH CODE	CODE SECTION/RULE	RESULT	PENALTY
1	B206	27-Misc, 28-Misc, BC -Misc	Sustained	\$1,250.00

Findings of Fact & Conclusions of Law

On 9/3/24, Respondent SHRI SIDHDHY VANAYAK, INC was issued a summons alleging a class 2 of MC section 1006.8.1 for having an unmarked water heater room with no remote shut-down for gas fired system at the point of egress, as required. The first scheduled hearing date was 11/15/24. On 1/4/25, the hearing was adjourned on the motion of the Petitioner for the testimony of the IO.

On 6/27/25, the hearing was conducted by telephone. Respondent appeared by its attorney Caroline Kane, Esq. Petitioner DOB appeared by its attorney Daniel Brickman, Esq.

Mr. Brickman rested on the summons.

Ms. Kane denied the charge but submitted no evidence in rebuttal.

I credit the allegations contained in the summons and find that Petitioner established a prima facie case for a class 2 violation of the cited section of law. I do not credit Respondent's denial and find that Respondent failed to submit any evidence in rebuttal. Accordingly, I sustain the summons and impose the mandatory penalty.

Didi Skaff

07/03/2025

07/03/2025

Didi Skaff, Hearing Officer

Date