



OFFICE OF ADMINISTRATIVE TRIALS AND HEARINGS
Hearings Division

DECISION

Michael Nacmias, Esq. - Nacmias Law Firm 592 Pacific Street 1st Floor Brooklyn, NY 11217	Summons No: 014140821H et al. (1 Summons) NEW YORK CITY FIRE DEPARTMENT, -against- DIXON & ASSOCIATES INC Hearing Date: 06/30/2025 Hearing Location: Remote Type of Hearing: By Telephone
---	--

Total Penalty Amount: \$1,425.00
Community Service(Hr): Not Applicable

SUMMONS #	SUMMARY DISPOSITION	DATE OF OCCURRENCE	PLACE OF OCCURRENCE
014140821H	Sustained	08/13/2024	39-40 22nd St Queens

LINE ITEM	OATH CODE	CODE SECTION/RULE	RESULT	PENALTY
1	BF09	VC9 .	Sustained	\$475.00
2	BF12	VC12 .	Sustained	\$950.00

Findings of Fact & Conclusions of Law

Frank Tamborino, Esq. appeared for Respondent and submitted evidence of correction of both charges for mitigation. Ahmad Al-Kaysey appeared for Petitioner and confirmed that the exit obstructions were removed and recommended a mitigated penalty of the VC9 charge. There was no evidence that the fire alarm panels were in good working order and he could not recommend a mitigated penalty for the VC12 charge.

Accordingly, the summons is sustained and a mitigated penalty of \$475 is assessed for the VC9 and a standard penalty of \$950 is assessed for the VC12.



07/03/2025

07/03/2025

Joan Silverman, Hearing Officer

Date